

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**

**LISTING No.** 7256-1448:102 Page 1 of 1

**CATEGORY:** Single/Multiple Station Smoke Detectors-Ionization

**LISTEE:** Code One Inc., 2820 Thatcher Road, Downers Grove IL 60515  
Contact: Tom Barakat (630) 719-6330

**DESIGN:** Models G-6, G-18, G-120, FXW-R and H hardwired smoke detectors. Models G-6, G-18, G-120 and FXW-R are suitable for multiple station use except Model H is a single station only. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as single or single/multiple station ionization smoke detectors.

\*These units can generate a distinctive temporal code pattern fire alarm signal in accordance with NFPA 72, 1996 Edition. Refer to listee's Installation Instructions Manual for details.

**NOTE:** \*The ionization type detectors are generally more effective at detecting fast, flaming fires which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen. The photoelectric type detectors are generally more effective at detecting slow, smoldering fires which smolder for hours before bursting into flame. Sources of these fires may include cigarettes burning in couches or bedding.

**XLf:** 7256-1093:110

\*Rev. 05-12-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 17, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy**

